CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7300-0694:206 Page 1 of 1

CATEGORY: Misc. Devices/Control Unit Accessories

Fire Control Instruments, 301 2nd Avenue, Waltham, MA 02451-1133 LISTEE:

Contact: Anthony J. Shalna (781) 471-3000*

DESIGN: Models MDL-FC, MDLW-FC sync modules. These modules are for use with listee's

separately listed compatible horns and strobes. Refer to listee's data sheet for additional

detailed product description and operational considerations.

12 or 24 VDC RATING:

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, product designation and UL label.

APPROVAL: Listed as sync modules for use with listee's separately listed compatible horns and strobes.

XLF: 7300-1209:179

*Rev. 06-11-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsementor recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

JUNE 21, 2003 Date Issued: Listing Expires June 30, 2004

DIANE K. AREND, Senior Deputy Authorized By:

Program Manager